

Certificate of Product Approval

Licensee:

IDH Cables Limited

Millbanks, New Ross, County Wexford, Ireland

Factory:

Millbanks, New Ross, County Wexford, Ireland

Test Report No:

H9TTA750

National Standard:

BS EN 50525-2-31:2011

European Standard:

EN 50525-2-31:2011

Type Description:

Single core non-sheathed cables with thermoplastic PVC insulation

Details:

N/A

Materials:

Insulation T1 1, Sheath NA

Brand Name:

N/A

Origin Mark:

IDH CABLES

PERMISSIBLE MARKS



BASEC ◁ HAR ▷

BLACK - 1cm
RED - 1cm
YELLOW - 3cm
THREAD

Note: The black - red - yellow thread has been registered in this country as an identification thread in the BSI "Register of colours of manufacturers' threads for electric cables and cords" for Verband Deutscher Elektrotechniker (VDE) e.V., Frankfurt, Germany. VDE has authorized BASEC to use this thread.

Please refer to the BASEC Product Certification Requirements

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 19/11/20

Date of original issue: 25/05/15

Check BASEC website to verify validity.

Superseded Certification No: 205/001/038,039,040,041 Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,
Registered in England No. 1150237, Tel: +44(0)1908267300
Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
19/02/2024

Type(s) and Range(s) of Approval

| Table | Code Designation | Conductor Class | Range of Cores | Min Nominal Size | Max Nominal Size |
|-------|------------------|-----------------|----------------|------------------|------------------|
| 4.1 | H07V-U | Class 1 | 1 | 1.5 | 2.5 |
| 4.1 | H07V-R | Class 2 | 1 | 1.5 | 16 |
| 4.2 | H07V-K | Class 5 | 1 | 1.5 | 10 |
| 4.3 | H05V-U | Class 1 | 1 | 0.5 | 1 |
| 4.3 | H05V-R | Class 2 | 1 | 0.5 | 1 |
| 4.4 | H05V-K | Class 5 | 1 | 0.5 | 1 |

This certificate is issued according to the rules of the HAR agreement. The certification Scheme meets the criteria for type 5 Scheme laid down in the ISO/IEC 17067:2013 (Type Testing, Factory Inspection with assurance of conformity by continuous sample testing, production surveillance and market surveillance). The certificate issued by any Certification Body adhering to the HAR Agreement has the same worth and validity in all the other Certification Bodies' countries.

Compliance with the requirements of the above listed Harmonised Standards carries a presumption of conformity with the essential safety requirements of Directive 2014/35/EU (Low Voltage Directive).

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 19/11/20

Date of original issue: 25/05/15

Check BASEC website to verify validity.

Superseded Certification No: 205/001/038,039,040,041 Page 2 of 2

