

## Product Certification Schedule

Schedule No: 210/001/009

Licensee: GENERAL CABLE CELCAT, AV. MARQUES DE POMBAL, 36/38  
MORELENA, 2715-055 PERO PINHEIRO, PORTUGAL

Factory: GENERAL CABLE CELCAT, AV. MARQUES DE POMBAL, 36/38  
MORELENA, 2715-055 PERO PINHEIRO, PORTUGAL

Specification: BS EN 50525-2-31:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 2-31: Cables for general applications - Single core non-sheathed cables with thermoplastic PVC insulation

Type of Cable: Clause 4.1 Table B.1 Clause 4.1 - Cables for fixed wiring - H07V-U and H07V-R Table B.1 - Cables with rigid conductor (450/750 V)

Range of Approval: 1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor. 1.5sqmm to 240sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Insulation - T11.

Origin Thread: Not Applicable

Origin Mark: General Cable 7 or GENERAL CABLE 7

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/11/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 08/11/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004