

Product Certification Schedule

Schedule No: 210/001/012
Licensee: GENERAL CABLE CELCAT, AV. MARQUES DE POMBAL, 36/38
MORELENA, 2715-055 PERO PINHEIRO, PORTUGAL
Factory: GENERAL CABLE CELCAT, AV. MARQUES DE POMBAL, 36/38
MORELENA, 2715-055 PERO PINHEIRO, PORTUGAL
Specification: BS 6231:2006 Incorporating Corrigendum No. 1 Electric cables - Single core
PVC insulated flexible cables of rated voltage 600/1000 V for switchgear and
controlgear wiring
Type of Cable: Table 2 PVC insulated flexible cable - Type CK
Range of Approval: 0.5sqmm to 240sqmm nominal cross-sectional area of conductors inclusive.
Single-core. Class 5 conductor. Insulation - T13.
Origin Thread: Not Applicable
Origin Mark: General Cable 7 or GENERAL CABLE 7

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/11/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 08/11/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004