

Product Certification Schedule

Schedule No: 215/001/007
Licensee: ALFANAR ELECTRIC, P.O. BOX 564, RIYADH 11383, SAUDI ARABIA
Factory: ALFANAR ELECTRIC, P.O. BOX 564, RIYADH 11383, SAUDI ARABIA
Specification: BS 7846:2015 Electric Cables - Thermosetting insulated, armoured, fire-resistant cables of rated voltage 600/1 000 V for fixed insulations, having low emission of smoke and corrosive gases when affected by fire - Specification.
Type of Cable: Tables 4, 5 and 6
Two-core, three-core and four-core 600/1000V cables with copper conductors
Range of Approval: 1.5sqmm to 400sqmm nominal cross-sectional area of conductors inclusive.
Two-core to four-core inclusive.
Resistance to Fire Categories F2 & F120.
Fire resistance to IEC 60331-21:1999.
Tested bend radius 8D.
Sheath - LTS1. Insulation - GP8.
Origin Thread: Not applicable
Origin Mark: alfanar

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 28/05/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 26/07/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004