

## Product Certification Schedule

Schedule No: 216/001/008

Licensee: DOHA CABLES, MIC COMMUNITY AREA, MESAIEED, PO BOX 22487, DOHA, QATAR

Factory: DOHA CABLES, MIC COMMUNITY AREA, MESAIEED, PO BOX 22487, DOHA, QATAR

Specification: BS 7846:2015 Electric Cables - Thermosetting insulated, armoured, fire-resistant cables of rated voltage 600/1 000 V for fixed insulations, having low emission of smoke and corrosive gases when affected by fire - Specification.

Type of Cable: Tables 4, 5 and 6 Two core, three core and four core 600/1000V cables with copper conductors

Range of Approval: 4sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Two core to four core inclusive. Resistance to fire Categories F2 & F120. Tested bend radius 8D. Sheath - LTS1. Insulation - GP8.

Origin Thread: Not Applicable

Origin Mark: DOHA CABLES

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 02/06/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 04/06/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004