BASEC
BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No:	216/001/014
Licensee:	DOHA CABLES, MIC COMMUNITY AREA, MESAIEED, PO BOX 22487, DOHA, QATAR
Factory:	DOHA CABLES, MIC COMMUNITY AREA, MESAIEED, PO BOX 22487, DOHA, QATAR
Specification:	BS 6724:2016 Electric cables - Thermosetting insulated, armoured cables of rated voltages of 600/1 000 V and 1 900/3 300 V for fixed installations, having low emission of smoke and corrosive gases when affected by fire - Specification
Type of Cable:	Tables 5, 6 and 7. Two-core, three-core and four-core 600/1 000 V cables with copper conductors
Range of Approval:	1.5sqmm to 35sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Class 2 circular conductor. 50sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Class 2 shaped conductor. Sheath - LTS1. Insulation - GP8.
Origin Thread:	Not Applicable
Origin Mark:	DOHA CABLES

PERMISSIBLE MARKS

BASEC

YELLOW ACETATE THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 02/06/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 17/07/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

UKAS PRODUCT CERTIFICATION 0004