

Product Certification Schedule

Schedule No: 219/001/001

Licensee: PHELPS DODGE INTERNATIONAL (THAILAND) LIMITED, 16TH FLOOR, MANEEYA CENTER BUILDING, 518/5 PLOENCHIT ROAD, LUMPINEE, PATHUMWAN, BANGKOK 10330, THAILAND

Factory: PHELPS DODGE INTERNATIONAL (THAILAND) LIMITED, 9/9 MOO 4, T.NIKHOMPATTANA, A.NIKHOMPATTANA, RAYONG 21180, THAILAND

Specification: BS 5467:2016 Incorporating Corrigendum No. 1 Electric cables. Thermosetting insulated, armoured cables of rated voltages of 600/1 000 V and 1 900/3 300 V for fixed installations. Specification

Type of Cable: Tables 5, 6 and 7
Two-core, three-core and four-core 600/1000V cables with copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Two-core to three-core inclusive. Class 2 circular conductor.
1.5sqmm to 35sqmm nominal cross-sectional area of conductors inclusive. Four-core. Class 2 circular conductor.
25sqmm to 50sqmm nominal cross-sectional area of conductors inclusive. Four-core. Class 2 shaped conductor.
Sheath - Type 9. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: PHELPS DODGE

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/10/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 05/09/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004