

Product Certification Schedule

Schedule No:	220/001/001
Licensee:	ADA ILETKEN KABLO SAN. A.S., ÇERKESLI O.S.B. MAH., IMES-8 CAD. IMES O.S.B. 21, DILOVASI / KOCAELI, TURKEY
Factory:	ADA ILETKEN KABLO SAN. A.S., ÇERKESLI O.S.B. MAH., IMES-8 CAD. IMES O.S.B. 21, DILOVASI / KOCAELI, TURKEY
Specification:	BS 6004:2012 Electric Cables - PVC insulated and PVC sheathed cables for voltages up to and including 300/500V, for electric power and lighting
Type of Cable:	Table 4 PVC insulated, PVC sheathed cable with circuit protective conductor (CPC), 300/500 V, single core 6241Y, flat twin 6242Y and flat 3-core 6243Y
HAR Document:	Not applicable
HAR Specification:	Not applicable
Range of Approval:	1.0sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Flat twin and flat 3-core. Class 1 conductor. 4sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat twin. Class 2 conductor. Sheath - Type 6. Insulation - T11.
Origin Thread:	Not applicable
Origin Mark:	ADA

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 13/12/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 14/12/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004