

Product Certification Schedule

Schedule No: 222/001/001

Licensee: DIKKAN KABLO, IZMIR-ANKARA KARAYOLU 29, KM NO. 336, ORGANIZE SANAYI BOLGESI, 35170, KEMALPASA, IZMIR, TURKEY

Factory: DIKKAN KABLO, IZMIR-ANKARA KARAYOLU 29, KM NO. 336, ORGANIZE SANAYI BOLGESI, 35170, KEMALPASA, IZMIR, TURKEY

Specification: BS 6004:2012 Electric Cables - PVC insulated and PVC sheathed cables for voltages up to and including 300/500V, for electric power and lighting

Type of Cable: Table 4 PVC insulated, PVC sheathed cable with circuit protective conductor (CPC), 300/500 V, single core 6241Y, flat twin 6242Y and flat 3-core 6243Y

Range of Approval: 1sqmm to 1.5sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor.
1sqmm to 2.5 sqmm nominal cross-sectional area of conductors inclusive. Flat twin to flat 3-core inclusive. Class 1 conductor.
4sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat twin to flat 3-core inclusive. Class 2 conductor.
Sheath - Type 6 Insulation - TI1 .

Origin Thread: Not applicable

Origin Mark: DIKKAN or DK

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 08/03/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 03/04/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004