

Product Certification Schedule

Schedule No: 222/001/003

Licensee: DIKKAN KABLO, IZMIR-ANKARA KARAYOLU 29, KM NO. 336, ORGANIZE SANAYI BOLGESI, 35170, KEMALPASA, IZMIR, TURKEY

Factory: DIKKAN KABLO, IZMIR-ANKARA KARAYOLU 29, KM NO. 336, ORGANIZE SANAYI BOLGESI, 35170, KEMALPASA, IZMIR, TURKEY

Specification: BS EN 50525-2-11:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) Part 2-11: Cables for general applications - Flexible cables with thermoplastic PVC insulation

Type of Cable: Clause 4.1 Light duty cables - H03VV-F and H03VVH2-F
Table B.1 Cables rated at 300/300 V

Range of Approval: 0.5sqmm to 0.75sqmm nominal cross-sectional area of conductors inclusive. Flat 2-core. Class 5 conductor.
0.5sqmm to 0.75sqmm nominal cross-sectional area of conductors inclusive. Circular 2-core to 4-core inclusive. Class 5 conductor.
Sheath - TM2. Insulation - TI2.

Origin Thread: Not applicable

Origin Mark: DIKKAN or DK

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 08/03/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 09/04/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004