BASEC
BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No:	222/001/011
Licensee:	DIKKAN KABLO, IZMIR-ANKARA KARAYOLU 29, KM NO. 336, ORGANIZE SANAYI BOLGESI, 35170, KEMALPASA, IZMIR, TURKEY
Factory:	DIKKAN KABLO, IZMIR-ANKARA KARAYOLU 29, KM NO. 336, ORGANIZE SANAYI BOLGESI, 35170, KEMALPASA, IZMIR, TURKEY
Specification:	BS EN 50525-2-11:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) Part 2-11: Cables for general applications - Flexible cables with thermoplastic PVC insulation
Type of Cable:	Clause 4.2 Table B.2 Clause 4.2 Ordinary duty cables - H05VV-F and H05VVH2-F Table B.2 Cables rated at 300/500 V
Range of Approval:	0.75sqmm to 1.5sqmm nominal cross-sectional area of conductors inclusive. Flat 2-core. Class 5 conductor. 0.75sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. Circular 2-core to 5-core inclusive. Class 5 conductor. Sheath - TM2. Insulation - TI2.
Origin Thread:	Not applicable
Origin Mark:	DIKKAN or DK

PERMISSIBLE MARKS

BASEC

YELLOW ACETATE THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 08/03/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 30/05/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

UKAS PRODUCT CERTIFICATION 0004