

Product Certification Schedule

Schedule No: 223/001/005
Licensee: VATAN KABLO METAL END. VE TIC. A.S., A BLOK KAT 11 NO: 1385 OKMEYDANI, ISTANBUL, TURKEY
Factory: VATAN KABLO METAL END. VE TIC. A.S., 111 SOKAK NO: 4/1 ERGENE, TEKIRDAG, TURKEY
Specification: BS 6724:2016 Incorporating Corrigenda Nos. 1 and 2 Electric cables - Thermosetting insulated, armoured cables of rated voltages of 600/1 000 V and 1 900/3 300 V for fixed installations, having low emission of smoke and corrosive gases when affected by fire
Type of Cable: Table 7 Four-core 600/1 000 V cables with copper conductors
Range of Approval: 1.5sqmm to 120sqmm nominal cross-sectional area of conductors inclusive. Four-core. Class 2 circular conductor. Sheath - LTS1. Insulation - GP8.
Origin Thread: Not applicable
Origin Mark: VATAN KABLO



PERMISSIBLE MARKS

BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 30/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 08/08/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004