

Product Certification Schedule

Schedule No: 224/001/001

Licensee: AEI CABLES LIMITED, PINETREE CENTRE, DURHAM ROAD, BIRTLEY, CHESTER LE STREET, COUNTY DURHAM, DH3 2TD

Factory: DUBAI CABLE COMPANY (PRIVATE) LIMITED, DUCAB-M1, P.O. BOX 9171, INDUSTRIAL CITY OF ABU DHABI, MUSSAFAH, ABU DHABI, UNITED ARAB EMIRATES

Specification: BS 7846:2015 Electric cables - Thermosetting insulated, armoured, fire resistant cables of rated voltage 600/1000 V for fixed installations, having low emission of smoke and corrosive gases when affected by fire - Specification

Type of Cable: Tables 5 & 6 Three-core and four-core 600/1000V cables with copper conductors. Mica tape insulation over the conductor.

Range of Approval: 16sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Three-core to four-core inclusive. Resistance to fire - Category F120. Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: AEI B

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 18/06/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 18/05/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

