

Certificate of Product Approval

Licensee:

Tecnikabel S.p.A. (Almese)

Via Brandizzo 243, Volpiano, 10088, TO, Italy

Factory:

243 Via Brandizzo, Via Brandizzo, 10088, Volpiano (TO), Italy

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

ENHANCED 120. Additionally tested to BS 6387 Categories C, W & Z.

Materials:

Insulation EI 5, Sheath LTS 3

Brand Name:

Origin Mark:

TECNIKABEL (A)

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals
Service for Cables

Tony Lioveri

Date: 20/07/2021

Date of original issue: 07/03/2018

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
02/07/2024

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	N/A	2	1.5	4
2	N/A	N/A	3	1.5	4
2	N/A	N/A	4	1.5	4

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 20/07/2021

Date of original issue: 07/03/2018

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,
Registered in England No. 1150237, Tel: +44(0)1908267300
Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
02/07/2024