

## Product Certification Schedule

Schedule No: 226/001/002  
Licensee: TECNIKABEL S.P.A, 243 VIA BRANDIZZO, 10088 VOLPIANO (TO), ITALY  
Factory: TECNIKABEL S.P.A, VIA RIVERA 100, 10040 ALMESE (TO), ITALY  
Specification: BS 7629-1:2015 Electric Cables - Specification for 300/500 V fire resistant, screened, fixed installations cables having low emission of smoke and corrosive gases when affected by fire. Part 1 : Multicore cables  
Type of Cable: Table 2 Dimensions of 2-core, 3-core and 4-core cables  
Range of Approval: 1.5sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. 2-core to 4-core inclusive. ENHANCED 120. Additionally tested to BS 6387 Categories C, W & Z. Sheath - LTS3. Insulation - EI5  
Origin Thread: Not Applicable  
Origin Mark: TECNIKABEL (A)

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 02/07/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 03/08/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004