



Certificate of Product Approval

Licensee:

British Cables Company Limited

Delaunays Road

Blackley, Manchester, M9 8FP, Lancashire, United Kingdom

Factory:

Delaunays Road

Blackley, Manchester, M9 8FP, Lancashire, United Kingdom

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

Standard 60. Additionally tested to BS 6387 categories C, W and Z.

Materials:

Insulation EI 2, Sheath LTS 3

Brand Name:

FLAM-GUARD 200 (FG200)

Origin Mark:

British Cables Company or BT Cables

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of
BASEC Group Ltd

Date: 06/12/2023

Date of original issue: 30/08/2023

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
15/06/2024



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 1 & 2	2	1.5	4
2	N/A	Class 1 & 2	3	1.5	4
2	N/A	Class 1 & 2	4	1.5	4

Signed for and on behalf of
BASEC Group Ltd

Date: 06/12/2023

Date of original issue: 30/08/2023

Check BASEC website to verify validity.

Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
15/06/2024