



Certificate No: 236/001/007

Issue No: 4

Certificate of Product Approval

Licensee:

British Cables Company Limited

Delaunays Road

Blackley, Manchester, M9 8FP, Lancashire, United Kingdom

Factory: Delaunays Road

Blackley, Manchester, M9 8FP, Lancashire, United Kingdom

Standard: BS 7629-1:2015

Description:
Fire resistant screened cables

Details:

Standard 60. Additionally tested to BS 6387 categories C, W and Z

Materials: Insulation El 2, Sheath LTS 3

Brand Name: FLAM-GUARD 200 (FG200)

Origin Mark: British Cables Company or BT Cables

Permissible Approval Marks:





BASEC name

BASEC roundel

Signed for and on behalf of BASEC Group Ltd

lukky Date: 22/05/2024

Date of original issue: 30/08/2023 Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK Registered in England No. 13950143, Tel: +44 (0)1908 267300 Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)





Expiry date: 15/06/2027





Certificate No: 236/001/007

Issue No: 4

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 1 & 2	2	1.5	4
2	N/A	Class 1 & 2	3	1.5	4
2	N/A	Class 1 & 2	4	1.5	4

Signed for and on behalf of BASEC Group Ltd

and plufter Date: 22/05/2024

Date of original issue: 30/08/2023 Check BASEC website to verify validity. Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK Registered in England No.13950143, Tel: +44 (0)1908 267300 Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



